

<h1>PPPL</h1>	PRINCETON PLASMA PHYSICS LABORATORY ES&H DIRECTIVES		
	ES&HD 5008 SECTION 5, APPENDIX A, TABLE 3 PPPL Occupancy Classifications		
Approved	Date: 04/16/02	Revision 3	Page 1 of 1

APPENDIX A
Table 3
PPPL Occupancy Classifications

Occupancy Type	PPPL Facility	Definition
Business	<ul style="list-style-type: none"> - Administration Building and Wing - Shop Building, 2nd Floor, - Maintenance Building, 2nd Floor - Emergency Services Building Offices - New Engineering Wing 	<p>Offices (minor offices incidental to another occupancy are not included).</p> <p>Small lecture rooms with occupancy load less than 50 people</p>
Industrial	<ul style="list-style-type: none"> - D-Site - Laboratory Building - Shop Building, 1st Floor - CS Building - RF Building - ESAT - Maintenance Building, 1st Floor - CAS/RESA Building - CASL 	<p>Experimental Areas</p> <p>Laboratories</p> <p>Boiler Rooms</p> <p>Mechanical Equipment Rooms</p> <p>Shops</p>
Storage	<ul style="list-style-type: none"> - Warehouses - Emergency Vehicle Building, Engine Room 	
Assembly	<ul style="list-style-type: none"> - Cafeteria - MBG Auditorium 	<p>Lecture Rooms with occupancy Load equal to or greater than 50 people</p>
Health Care	<ul style="list-style-type: none"> -Dispensary 	